

VOC Content Test Certificate

Monday February 4th, 2008

Manufacturer: RLA Polymers Pty Ltd

215 Colchester Road

Kilsyth Victoria 3137

Sample Description: GS200 Adhesive

Date Tested: October 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design IEQ-13	GS200 Adhesive
Carpet Adhesive 50 grams per Litre as VOC content material	11 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0710-21