

VOC Content Test Certificate

Friday June 20th, 2008

Manufacturer: RLA Polymers Pty Ltd
 215 Colchester Road
 Kilsyth Victoria 3137

Sample Description: GS300 Adhesive

Date Tested: June 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	GS300 Adhesive
Indoor carpet adhesive 50 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	GS300 Adhesive
Indoor carpet adhesive 50 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0806-26