



Consulting Enterprises in Technology

SCIENTIFIC CONSULTANTS IN RISK ASSESSMENT AND MANAGEMENT, PRODUCTS, PROCESSES, OH&S, ENVIRONMENT

VOC Content Test Certificate

Friday July 4th, 2008

Manufacturer: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth Victoria 3137)

Sample Description: GS400 floor primer

Date Tested: March 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ -13 Green Star Office Interiors V1.1 IEQ -11	GS400
Sub-floor Adhesive 50 grams per Litre as VOC content material	10 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ -13	GS400
Sub-floor Adhesive 50 grams per Litre as VOC content material	10 grams per Litre as VOC content per coating

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant