

VOC Content Test Certificate

Friday June 20th, 2008

Manufacturer: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth Victoria 3137)

Sample Description: GS820 epoxy coating

Date Tested: June 2008

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ -13 Green Star Office Interiors V1.1 IEQ -11	GS820
Interior Sealer 65 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ -13	GS820
One or two pack performance coating for floors 140 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0806-05