

VOC Content Test Certificate

Thursday October 23rd, 2008

Manufacturer: RLA Polymers Pty Ltd

215 Colchester Road

Kilsyth Victoria 3137

Sample Description: R6805 Stud Adhesive

Date Tested: October 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	R6805 Stud Adhesive
Dry wall and panel adhesive 50 grams per Litre as VOC content coating	45 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	R6805 Stud Adhesive
Dry wall and panel adhesive 50 grams per Litre as VOC content coating	45 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0810-18